



JEFFERSON PARISH

Department of Purchasing

Michael S. Yenni
Parish President

Brenda J. Campos
Director

October 11, 2016

ADDENDUM #2

Bid No.: 50-00117617

Bid Opening Date: October 13, 2016
REVISED OPENING DATE: October 25, 2016

For: Provide and install one (1) Multi-zone Air Handler Unit and six (6) Water source heating coils at First Parish Court Building.

CLARIFICATIONS:

BID DUE DATE HAS BEEN POSTPONED TO OCTOBER 25, 2016

QUESTIONS:

1. In Section G Bullet Point 11:
Please clarify which pumps require replacement of basket type or wye type strainers?

Answer:

Remove bullet point 11 entirely from Section G.

2. Section 7.1 Duct Cleaning (Alternate 1)
Does the entire internal duct liner require anti-microbial paint or just portions that contain visible growth?

Answer:

Entire internal duct will require Anti-Microbial paint.

Sincerely,

Sidney Duffy

Sidney Duffy, Buyer II
Jefferson Parish Purchasing Department



JEFFERSON PARISH

Department of Purchasing

Michael S. Yenni
Parish President

Brenda J. Campos
Director

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form as indicated. Failure to do so will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.